



# WATER VAULT

NOT TO SCALE

- NOTES:**
1. FIRE HYDRANT TO BE WITHIN 50 FEET OF THE FIRE DEPARTMENT CONNECTION (FDC) AND ARRANGED IN SUCH A MANNER THAT NEITHER THE HOSE FROM THE FIRE HYDRANT TO THE FIRE TRUCK NOR THE HOSE FROM THE FIRE TRUCK TO THE FDC CROSS A MOTORIZED VEHICLE TRAVEL LANE.
  2. ALL WATER LINES AND APPURTENANCES TO BE CLEARLY IDENTIFIED AND LABELED.
  3. ALL WATER LINES TO BE EVEN NUMBERED SIZED (I.E. 2", 4", 6",.....)
  4. VAULT LID TO EXTEND THE ENTIRE LENGTH OF VAULT SO AS TO ALLOW REMOVAL OF ENTIRE VAULT ASSEMBLY AT ON TIME.
  5. ALL EXPOSED STANDPIPES TO BE PAINTED SILVER.
  6. ALL MATERIALS TO BE APPROVED BY PUBLIC WORKS.

DEPARTMENT OF PUBLIC WORKS CITY OF WOODSTOCK, GA 103 ARNOLD MILL ROAD WOODSTOCK, GA 30188	JOB TITLE <b>FIRE</b>	SHEET TITLE <b>WATER VAULT DETAIL</b>
JOB NUMBER: 06009	DETAIL NUMBER <b>F-101</b>	
JUNE 2008		